

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0065:142 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Faraday Inc., 805 S. Maumee Street, Tecumseh, MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Models 140* and 141 horns. Unit is an electronic horn employing a weather resistive housing with provisions for connection of conduit, reentry horn two printed wiring boards for electronic circuitry. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 141: 24 VDC
*140: 24 VAC or 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as electronic horn for use with separately listed compatible fire alarm control units. *Model 140 is intended for general alarm only while Model 141 is intended for fire alarm use. Suitable for indoor and outdoor use.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 09-30-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager